

SANITARY CERTIFICATE

This is to certify that, the accommodation provided in each Classroom of **GLOBAL VIEW SCHOOL** (Under Buddha Educational Society) of Ramabhadrapuram is situated at Sri Balaji Green City, Opp: Bobbili Smart City Township, Ramabhadrapuram Village, Ramabhadrapuram Mandalam, Vizianagaram District, Andhra Pradesh.

This certificate should be grant renewed for a period of 5 years from the **Academic year 2023-24 to 2028-29**

The building consists of three floors. The above school building is sufficient for the pupils and properly ventilated with sufficient lighting, and the building is Maintained neat and clean, the toilet arrangements are adequate and satisfactory in public health point of view also protected drinking water is provided in the above institute.


MEDICAL OFFICER
Primary Health Centre,
RAMABHADRAPURAM
Vizianagaram Dist

Government of Andhra Pradesh
RURAL WATER SUPPLY & SANITATION DEPARTMENT
Report on Chemical Analysis of Water (Drinking)
 General (Physico-chemical Parameters)

Name of the District : VIZIANAGARAM

Name of the Water Testing Laboratory : VIZIANAGARAM DISTRICT LEVEL LABORATORY

Received From : Global View School, Ramabhadrapuram

Date of Received :

Sl. No.	Name of the Mandal	Gram Panchayat	Source code / Location	Type of Source	Colour	Turbidity	pH	EC	Total Dissolved Solids	Total Alkalinity CaCO_3	Total Hardness as CaCO_3	Calcium as Ca^{++}	Magnesium as Mg^{++}	Chloride as Cl^-	Fluoride as F^-	Nitrate as NO_3^-	Sulfate as SO_4^{--}	Iron as Fe	Sodium as Na^+	Potassium as K^+
S:10500-2012 Permissible limits			Requirement (Acceptable limits)		5.0	1.0	6.5-8.5	--	500	200	200	75	30	250	1	45.0	200	0.3	--	--
			Permissible limits in the absence of alternate source		15.0	5.0	No relaxation	--	2000	600	600	200	100	1000	1.5	No relaxation	400	1	--	--
Units					Pt-Co units	Colour	Colour	Micro Simens	mg./lit.	mg./lit.	mg./lit.	mg./lit.	mg./lit.	mg./lit.	mg./lit.	mg./lit.	mg./lit.	mg./lit.	mg./lit.	mg./lit.
			5	Global View School, Rap	BW	-	0.2	7.49	1149	746	536	160	37	16	88	1.10	29.12	30.05	0.15	-

Bacteriological Analysis :- Bacteriologically Negative

Signature of Lab. Chemist / Lab. Microbiologist
S. V. N. Narayana Rao
 RWS & S. Vizianagaram